



CONTROLLED DOOR CLOSING DEVICES

Certificate number: IFCC 1482

This is a product certificate to certify that

RUTLAND UK

Whittington Way,
Chesterfield
S41 9AG
UK
Telephone no. 01246 261491

Who manufacture the following Overhead Door Closer:

Responder 24

have satisfied the requirements of the SDP08 Controlled Door Closer scheme. This includes the testing of products to **EN 1634-1** and **EN 1155** standard, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.



First Issued: 06 Feb 2019
Valid to: 05 Feb 2024
Issue No: 1



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

Rutland Responder 24, Electromagnetic Door Closer

Acceptable doorset types and fire resistance periods are identified in the table below: -

Approved Door Types						
FR	IMM	MM	TT	ITT	ITM	ITC
FD20	✓	✓	X	✓	X	X
FD30	✓	✓	X	✓	X	X
FD60	✓	✓	X	✓	X	X
FD90	✓	✓	X	X	X	X
FD120	✓	✓	X	X	X	X
FD240	✓	✓	X	X	X	X
E20	✓	✓	X	✓	X	X
EI20	✓	✓	X	✓	X	X
E30	✓	✓	X	✓	X	X
EI30	✓	✓	X	✓	X	X
E60	✓	✓	X	✓	X	X
EI60	✓	✓	X	✓	X	X
E90	✓	✓	X	X	X	X
EI90	✓	✓	X	X	X	X
E120	✓	✓	X	X	X	X
EI120	✓	✓	X	X	X	X
E240	✓	✓	X	X	X	X
EI240	✓	✓	X	X	X	X

Key

Type TT - 20 minute doorsets that consist of non-metallic leaves in timber frames that do not contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Classification

Category of use	Durability	Power Level	Fire	Safety	Corrosion Rating
4	8	4	1	1	0

This approval only relates to its use with the door assemblies and configurations identified in PAR 18695 Rev 01:-

TT Timber Leaf & Timber Frame

May be fitted Standard, Parallel arm or Transom fixing position on previously tested single-acting, latched or unlatched, intumescent sealed timber door and timber frame assemblies.

IMM & MM Metal Leaf & Metal Frame

May be fitted Standard or Parallel arm fixing position to single-acting steel door assemblies, if required to the fire risk or non-fire-risk face of the leaf of previously tested uninsulating or insulating steel door leaf and frame assemblies.